

VENTILATION DOES NOT REMOVE TOBACCO SMOKE

N.C. Tobacco Prevention & Control Branch

“Exposures of nonsmokers to secondhand smoke (SHS) cannot be controlled by air cleaning or mechanical air-exchange” (U. S. Surgeon General Report, 2006, chapter 10, section 10)

Ventilation Systems and/or Smoking Rooms

These are ineffective and costly. There is no safe level of exposure to SHS, and there is no ventilation system that will prevent SHS from permeating nonsmoking areas. Ventilation sometimes removes odor and larger particles, but cannot remove the harmful chemicals and gases in SHS. Smoking rooms offer no protection for employees who work in those areas, putting employees at risk.

Ventilation Does Not Effectively Protect Nonsmokers from SHS

- Establishing a smoke-free environment is the only effective way to protect nonsmokers from SHS.
- There is no risk-free level of exposure to SHS. Even low levels of exposure can harm nonsmokers' health.
- Separating smokers from nonsmokers, cleaning the air, and ventilating buildings cannot eliminate secondhand smoke exposure.
- Current heating, ventilating, and air conditioning systems alone cannot control SHS exposure. In fact, these systems can distribute SHS throughout a building.
- The American Society of Heating, Refrigerating and Air-Conditioning Engineers (ASHRAE), a U.S. standard-setting body on ventilation issues, states that ventilation systems cannot remove SHS from indoor environments.
- Even separately enclosed, separately exhausted, negative-pressure smoking rooms cannot keep SHS from spilling into adjacent areas. In practice, employees are often required to enter such rooms in order to perform their job duties. Employees and patrons in such rooms are likely to be exposed to especially high levels of SHS.



NC DEPARTMENT OF
HEALTH AND HUMAN SERVICES
Division of Public Health

State of North Carolina • Department of Health and Human Services • Division of Public Health

www.ncdhhs.gov • www.tobaccopreventionandcontrol.ncdhhs.gov

N.C. DHHS is an equal opportunity employer and provider.

The American Society of Heating, Refrigerating and Air-Conditioning Engineers (ASHRAE), concludes that:

The medical community agree that SHS is a health risk, causing lung cancer and heart disease in adults, and both causing and worsening asthma, lower respiratory illnesses and other harms to the respiratory health of children.

Currently the only way to effectively eliminate the health risks associated with indoor exposure is to ban smoking indoors.

“Because of ASHRAE’s mission to act for the benefit of the public, it encourages elimination of smoking in the indoor environment as the optimal way to minimize (SHS) exposure. This definition includes smoke produced from the combustion of cannabis and controlled substances and the emissions produced by electronic smoking devices.”

References:

U.S. Department of Health and Human Services. [The Health Consequences of Involuntary Exposure to Tobacco Smoke: A Report of the Surgeon General](http://www.cdc.gov/tobacco/data_statistics/sgr/sgr_2006/index.htm). Atlanta, Georgia: U.S. Department of Health and Human Services, Centers for Disease Control and Prevention, Coordinating Center for Health Promotion, National Center for Chronic Disease Prevention and Health Promotion, Office on Smoking and Health, 2006 [cited 2006 Oct 23]. Available from: http://www.cdc.gov/tobacco/data_statistics/sgr/sgr_2006/index.htm

American Society of Heating, Refrigerating and Air-Conditioning Engineers. Environmental Tobacco Smoke: Position Document. Atlanta, Georgia: 2016.

American Society of Heating, Refrigerating and Air-Conditioning Engineers. “Ventilation for Acceptable Indoor Air Quality” ANSI/ASHRAE Addenda a, c, j, k, q, r, and s to ANSI/ASHRAE Standard 62.1-2013. Available from: https://www.ashrae.org/File%20Library/Technical%20Resources/Standards%20and%20Guidelines/Standards%20Addenda/62_1_2013_2015Supplement_20150203.pdf